


AD-A107 524

ARMY ENGINEER WATERWAYS EXPERIMENT STATION VICKSBURG--ETC F/G 13/3
EVALUATION OF TESTS FOR DETERMINING THE PUMPABILITY OF CONCRETE--ETC(U)
OCT 81 S A RAGAN
WES/MP/SL-81-29

UNCLASSIFIED

NL

1-14
AF
44-77534



END


DATE

FILMED

42-81

DTIC

LEVEL II



MISCELLANEOUS PAPER SL-81-29

EVALUATION OF TESTS FOR DETERMINING THE PUMPABILITY OF CONCRETE MIXTURES

by

Steven A. Ragan


Structures Laboratory

U. S. Army Engineer Waterways Experiment Station
P. O. Box 631, Vicksburg, Miss. 39180

October 1981

Final Report

Approved For Public Release; Distribution Unlimited



DTIC FILE CO

Prepared for Office, Chief of Engineers, U. S. Army
Washington, D. C. 20314

Under CWIS Work Unit 31138

DTIC
ELECTE
NOV 20 1981
S D

D

054

Destroy this report when no longer needed. Do not return
it to the originator.

The findings in this report are not to be construed as an official
Department of the Army position unless so designated
by other authorized documents.

The contents of this report are not to be used for
advertising, publication, or promotional purposes.
Citation of trade names does not constitute an
official endorsement or approval of the use of
such commercial products.

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER Miscellaneous Paper SL-81-29	2. GOVT ACCESSION NO. AD-A107524	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) EVALUATION OF TESTS FOR DETERMINING THE PUMPABILITY OF CONCRETE MIXTURES	5. TYPE OF REPORT & PERIOD COVERED Final Report	6. PERFORMING ORG. REPORT NUMBER
7. AUTHOR(s) Steven A. Ragan	8. CONTRACT OR GRANT NUMBER(s)	
9. PERFORMING ORGANIZATION NAME AND ADDRESS U. S. Army Engineer Waterways Experiment Station Structures Laboratory P. O. Box 631, Vicksburg, Miss. 39180	10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS CWIS Work Unit No. 31138	
11. CONTROLLING OFFICE NAME AND ADDRESS Office, Chief of Engineers, U. S. Army Washington, D. C. 20314	12. REPORT DATE Oct 1981	
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)	13. NUMBER OF PAGES 50	15. SECURITY CLASS. (of this report) Unclassified
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited.		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES Available from National Technical Information Service, 5285 Port Royal Road, Springfield, Va. 22151.		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Concrete mixtures Concrete pumps Concrete tests Laboratory tests		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) This report presents the results of an investigation to evaluate two methods currently proposed for determining concrete pumpability: (a) the pressure bleed test method and (b) a checklist analysis which examines 10 variables of concrete mixtures and their effects on concrete pumpability. Part of the investigation consisted of a laboratory study in which 14 mixtures containing a combination of both rounded (natural) and angular (crushed) coarse aggregate, natural and manu- factured fine aggregate, mineral admixtures, steel fibers, and a		

(Continued)

DD FORM 1 JAN 73 1473 EDITION OF 1 NOV 65 IS OBSOLETE

Unclassified
SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

20. ABSTRACT (Continued).

high-range water-reducing admixture were analyzed using both proposed procedures and then pumped. The other part comprised a field study in which two concrete mixtures were analyzed and then pumped at two project locations. One contained natural coarse and fine aggregate and the other contained manufactured coarse and fine aggregate. All concrete mixtures were air entrained.

It was concluded that the pressure bleed test method is effective only in determining the pumpability of concrete using a poorly maintained and leaky pump. The checklist analysis, although conservative, is a better indicator of pumpability and should be considered for inclusion in an appropriate Engineer Manual or Engineer Technical Letter.

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

PREFACE

This investigation was conducted in the Structures Laboratory (SL), U. S. Army Engineer Waterways Experiment Station (WES), under the sponsorship of the Office, Chief of Engineers, U. S. Army (OCE), as a part of Civil Works Investigational Studies Work Unit No. 31138, "New Technologies for Testing and Evaluating Concrete." Messrs. James A. Rhodes and Fred Anderson of the Structures Branch, Engineering Division, OCE, served as Technical Monitors.

The investigation was conducted under the direction of Mr. Bryant Mather, Chief, SL, and Mr. John Scanlon, Chief, Concrete Technology Division (CTD), SL. Messrs. K. L. Saucier, S. A. Ragan, W. B. Lee, and J. B. Eskridge actively participated in the investigation, and Mr. Ragan prepared the report.

The Commanders and Directors of WES during this investigation and the preparation and publication of this report were COL John L. Cannon, CE, COL Nelson P. Conover, CE, and COL Tilford C. Creel, CE. Technical Director was Mr. F. R. Brown.

Accession For	
NTIS GRA&I	<input checked="" type="checkbox"/>
DTIC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By	
Distribution/	
Availability Codes	
Dist	Avail and/or Special
A	

DTIC
ELECTE
S NOV 20 1981 D
D

CONTENTS

	<u>Page</u>
PREFACE	1
CONVERSION FACTORS, INCH-POUND TO METRIC (SI)	
UNITS OF MEASUREMENT.	3
PART I: INTRODUCTION	4
Background.	4
Purpose	5
Scope	5
PART II: MATERIALS, MIXTURES, APPARATUS, AND PROCEDURES.	6
Materials	6
Mixtures.	7
Apparatus and Procedures.	8
PART III: TESTS.	13
Pressure Bleed Test	13
Checklist Analysis.	14
PART IV: DISCUSSION OF TEST RESULTS.	15
Pressure Bleed Test	15
Checklist Analysis.	17
PART V: CONCLUSIONS AND RECOMMENDATIONS.	35
REFERENCES.	36
TABLES 1-12	

CONVERSION FACTORS, INCH-POUND TO METRIC (SI)
UNITS OF MEASUREMENT

Inch-pound units of measurement used in this report can be converted to metric (SI) units as follows:

<u>Multiply</u>	<u>By</u>	<u>To Obtain</u>
cubic feet	0.02831685	cubic metres
cubic yards per hour	0.76455486	cubic metres per hour
feet	0.3048	metres
inches	2.54	centimetres
inches	25.4	millimetres
ounces (U. S. fluid)	29.57353	cubic centimetres
pounds (force) per square inch	0.00689476	megapascals
pounds (mass)	0.45359237	kilograms
pounds (mass) per cubic yard	0.59327642	kilograms per cubic metre

EVALUATION OF TESTS FOR DETERMINING THE PUMPABILITY OF
CONCRETE MIXTURES

PART I: INTRODUCTION

Background

1. Pumping has been used as a means of transporting freshly mixed concrete in the United States since the early 1930's. There has been a large increase in the quantity of concrete conveyed by pumping since the mid-1960's primarily due to the development of mobile hydraulic pumps; the introduction of rubber, plastic, and flexible metal hoses; and the use of power-assisted booms.

2. The increased acceptance of concrete pumping was accompanied by the realization that normal-weight concrete mixtures suitable for transporting and placing by conventional methods were not always pumpable with available equipment. The failure of a mixture to pump normally results from either (Parker et al. 1973):

- a. Excessive pumping pressures force excess water to bleed through the mixture without moving the mass.
- b. The capacity of the pump is exceeded by the combination of head, pipeline friction, and resistance of the mixture to internal deformation.

A number of laboratory procedures have been proposed for analyzing and comparing the pumpability of concrete mixtures (Parker et al. 1973, Gray 1962, Best and Lane 1980). Currently, however, evaluation under actual field conditions is the only accepted method of testing a mixture for pumpability. A test method which could be performed quickly either in the laboratory or in the field and which would correctly evaluate the relative pumpability of a concrete mixture would be of benefit.

Purpose

3. The purpose of this investigation was to evaluate the effectiveness and feasibility of the following two currently proposed methods of determining the pumpability of concrete mixtures:

- a. The pressure bleed test.
- b. A checklist analysis which examines 10 variables of concrete mixtures and their effects on concrete pumpability.

Scope

4. The investigation consisted of a laboratory and a field study. Fourteen mixtures were analyzed for potential pumpability in the laboratory study using both of the proposed procedures and then pumped to determine actual pumpability. The mixtures contained a combination of both rounded (natural) and angular (crushed) coarse aggregate, natural and manufactured fine aggregate, mineral admixtures, steel fibers, and a high-range water-reducing admixture. All laboratory mixtures were air entrained. The field study consisted of using the proposed methods to evaluate the pumpability of concrete mixtures which were then pumped for use at two project locations. One of the mixtures contained a 1-1/2-in.* (38.1-mm) maximum-size rounded coarse aggregate and a natural fine aggregate, while the second contained a 1-1/2-in. (38.1-mm) maximum-size crushed coarse aggregate and a manufactured fine aggregate. Both of the field mixtures were air entrained.

>

* A table of factors for converting inch-pound units of measurement to metric (SI) units is presented on page 3.

PART II: MATERIALS, MIXTURES, APPARATUS, AND PROCEDURES

Materials

Laboratory study

5. Type I portland cement (RC-728)^{*} was used in the laboratory study. Table 1 gives the chemical and physical properties of the cement. Natural sand fine aggregate (WES-1 S-4(51)) and natural rounded gravel coarse aggregate (CRD G-42) from Mississippi were used in seven of the laboratory mixtures. Crushed limestone fine aggregate (CRD MS-27) and crushed limestone coarse aggregates (CL-2 G-1 and CRD G-40) from Alabama were used in the remaining seven laboratory mixtures. The physical properties and gradings of the aggregates are given in Tables 2 and 3. The air-entraining admixture (AEA-956) used was a solution of neutralized Vinsol resin. Other materials used in the laboratory mixtures included:

- a. Pozzolan (fly ash, AD-474); the chemical and physical properties are presented in Table 4.
- b. A high-range water-reducing admixture consisting of a condensation product of melamine and formaldehyde.
- c. A commercially available "pump aid" marketed as a cement slurry friction reducer.
- d. Straight steel fibers having nominal dimensions 0.010 by 0.022 by 1.0 in. (0.25 by 0.56 by 25.4 mm).

Field study

6. Morganza Control Structure Stilling Basin, New Orleans District. The stilling basin was constructed of concrete containing Type I portland cement (NO-14 C-3). Natural gravel coarse aggregate (NO-14 G-8) and natural sand fine aggregate (NO-14 S-2) from Louisiana were used in the concrete mixture. The physical properties and gradings of the aggregates are given in Table 5. The air-entraining admixture used was a solution of neutralized Vinsol resin.

7. Clarence Cannon Reservoir, Re-Regulation Dam and Spillway, St. Louis District. This structure was constructed of concrete containing

* Structures Laboratory materials identification number.

Type II portland cement (STL-43 C-1). The physical and chemical properties of the cement are given in Table 6. Crushed limestone coarse and fine aggregates (STL-43 G-1 and STL-43 S-1, respectively) from Missouri were used in the concrete mixture. The physical properties and gradings of the aggregates are given in Table 7. The air-entraining admixture (STL-43 AEA-1) was a solution of neutralized Vinsol resin. A Type B retarding admixture (STL-43 AD-1) conforming to the requirements of ASTM C-494 (American Society for Testing and Materials 1980) was also used in the mixture.

Mixtures

Laboratory study

8. The following 14 concrete mixtures were proportioned in the laboratory study and used to evaluate the proposed test procedures:

Mixture	Water-Cement Ratio by Mass	Cement Content		Slump (ASTM C-143)*		Air Content, Pressure Method (ASTM C-231)* %
		lb/yd ³	kg/m ³	in.	mm	
1	0.55	400	237	7	175	4.5
2	0.53	400	237	5	125	7.5
3	0.46	400	237	3	75	3.0
4	0.53	400	237	3-3/4	95	5.3
5	0.53	400	237	5	125	6.5
6	0.48	650	387	6-3/4	170	3.5
7	0.40	518	307	3	75	4.6
8	0.71	400	237	4	100	4.4
9	0.71	400	237	2-1/4	55	3.5
10	0.71	400	237	3-1/4	80	2.5
11	0.73	400	237	4-1/2	115	3.5
12	0.73	400	237	6-1/4	160	2.5
13	0.50	518**	307	4-3/4	120	2.7
14	0.43	700	415	3	75	4.5

* ASTM (1980).

** Fly ash, 25 percent by solid volume of cement.

The proportions for each mixture are given in Table 8.

Field study

9. The following two concrete mixtures were used in the field study to investigate the effectiveness of the two proposed test methods:

Project	Water-Cement Ratio by Mass	Cement Content		Slump (ASTM C-143)*		Air Content Pressure Method (ASTM C-231)* %
		lb/yd ³	kg/m ³	in.	mm	
Morganza Stilling Basin	0.53	450	267	2	50	5.0
Clarence Cannon Re-Regulating Dam	0.50	662	393	4	100	4.5

* ASTM (1980).

The proportions for each mixture are given in Table 9.

Apparatus and Procedures

Pressure bleed test

10. The bleed test apparatus used in the investigation was developed by Browne and Bamforth (1977) and a schematic of it is shown in Figure 1. It consists of a 5-in.-diam (125-mm) cylinder with a removable top and base. The top portion of the device houses a piston which is attached to the plunger of a double-acting hydraulic jack. The hand-operated pump which supplies pressure to the jack has a four-way valve which allows for the movement of the piston in two directions. The base of the apparatus has a tap inserted into a small bleed hole. This hole is covered with a No. 50-mesh wire gauze to prevent tap blockages.

11. Concrete is placed into the cylinder in two equal layers, each of which is lightly tamped. The level of the top layer is brought to within 1/2 in. (12 mm) of the top of the cylinder, and the top of the apparatus then attached. The bleed tap is closed and concrete is subjected to a pressure of 500 psi (3.5 MPa) using the hand pump. This value is defined by Browne and Bamforth as a typical pressure at the pump end




Figure 1. Pressure bleed test apparatus

of an 820-ft (250-m) horizontal line. The bleed tap is then opened and the volume of water emitted is measured at 10 sec (V_{10}) and 140 sec (V_{140}). The difference between the two readings ($V_{140} - V_{10}$) is recorded as water emitted. A large value of $V_{140} - V_{10}$ will reportedly result in a more pumpable mixture having less tendency to bleed. Browne and Bamforth have established minimum allowable values of $V_{140} - V_{10}$ for various levels of concrete slump. This relationship is shown in Figure 2. When the emitted water value of a mixture having a particular slump exceeds the minimum allowable value, the concrete should be pumpable.

Checklist analysis

12. The checklist worksheet prepared by Anderson (1977) and used in this investigation is shown in Figure 3. The procedure consists of determining the following individual characteristics of a concrete mixture:

- a. Coarse aggregate-total aggregate ratio (CA/TA) by solid volume.
- b. Fineness modulus (FM) of fine aggregate (FA).
- c. Cumulative percent of fine aggregate finer than the 300- μ m (No. 50) and 150- μ m (No. 100) sieves.
- d. Cement or equivalent fine-fines content.
- e. Combined gradation of the coarse and fine aggregates.
- g. Slump.
- h. Air content.
- i. Aggregate saturation (lightweight concrete).
- j. Aggregate shape.
- k. Admixtures.

Analyzed collectively, these characteristics reportedly provide a relative measure of concrete pumpability. Anderson gives recommended allowable variances for the first seven characteristics. If one or more of the characteristics have values outside of these recommended ranges, the mixture should be given a pumpability rating of either borderline or nonpumpable.




Figure 2. Relationship between concrete slump and water emitted during pressure bleed test

CHARACTERISTIC		MSA, WT, MIN. LINE DIA	ACTUAL	NG	?	OK	REC ADJUSTMENT
CA/TA RATIO (BY VOLUME)		50% / LARGER MSA					
		TO MORE RD AGG					
		65% / LOW FM OF FA					
FM OF FA	N. WT.	2.4 - 3.0					
	LT. WT.	2.2 - 2.8					
CUM % FA PASSING		#50 SIEVE 15-30%					
		#100 SIEVE 5-10%					
CEMENT OR EQUIV CONTENT		470 lb (213 kg)					
GRADATION CURVE		ABOVE BOUNDARY LIMIT					
SLUMP		2-6 IN. (5-15 cm)					
AIR CONTENT		6% MAX					
AGGREGATE SATURATION		(LT WT) - MIN OF 24 HR ASTM ABSORPTION					
AGGREGATE SHAPE		ROUNDED OR CA					
		IRREGULAR FA					
ADMIXTURES							
EVALUATION OF PUMPABILITY							




Figure 3. Checklist analysis worksheet

PART III: TESTS

Pressure Bleed Test

Laboratory study

13. The 14 mixtures proportioned in the laboratory were used to study the effects on the pressure bleed test results of various aggregate types and shapes, cementitious contents, slumps, fine aggregate-to-total-aggregate ratios, and admixtures.

14. Actual pumping tests were conducted on each mixture following the performance of the pressure bleed test. Two piston-type pumps were selected for use based on serviceability. Laboratory pump No. 1 was approximately 12 years old and in poor general repair. Several of the line couplings and seals were loosely connected. The rated capacity of the pump was 40 yd³/hr (31 m³/hr). Laboratory pump No. 2 was new and in good general repair, and the pump's valves and line couplings fit tightly. The rated capacity of laboratory pump No. 2 was 60 yd³/hr (46 m³/hr). A 4-in.-ID (100-mm) line size was used for both pumps. The layout for laboratory pump No. 1 consisted of approximately 82 ft (25 m) of slick line arranged in an oval pattern so that concrete would be returned to the pump hopper. Approximately 213 ft (65 m) of slick line and 33 ft (10 m) of flexible hose were positioned to recirculate concrete back to the hopper of laboratory pump No. 2.

Field study

15. Morganza Control Structure Stilling Basin. The pressure bleed test was conducted at the project site while a concrete pumping operation was in progress. Concrete was pumped approximately 100 ft (30 m) through a 5-in.-ID (125-mm) slick line using a dual-valve, truck-mounted, piston-type pump (field pump No. 1). The rated capacity of the pump was 110 yd³/hr (84 m³/hr). The concrete samples tested were obtained by diverting truck mixer discharge from the pump hopper into a sample container. Two pressure bleed tests were conducted.

16. Clarence Cannon Reservoir, Re-Regulation Dam and Spillway. The pressure bleed test was conducted at this project site also during

the progress of a concrete pumping operation. A dual-valve, truck-mounted piston-type pump (field pump No. 2) having a rated capacity of 95 yd³/hr (73 m³/hr) pumped the concrete through a 5-in.-ID (125-mm) slick line for approximately 120 ft (37 m). Concrete samples used in the tests were obtained by interrupting the flow from bottom-dump buckets with a sample receptacle. Three tests were conducted at the site. Two of these were performed using unmodified samples. One of the tests was conducted on a sample which was wet-sieved over a 25.0-mm (1-in.) sieve in order to evaluate the effects of different maximum aggregate sizes on the bleed test results.

Checklist Analysis

17. Each of the mixtures investigated in the laboratory and field studies was evaluated using the checklist analysis. Those mixtures having 1 or more of the 10 characteristics outside the recommended range were generally rated as "borderline" or "not good" with respect to relative pumpability.

PART IV: DISCUSSION OF TEST RESULTS

Pressure Bleed Test

Laboratory study

18. The results of the pressure bleed and pumping tests conducted in the laboratory investigation are shown in Table 10. Although each of the 14 mixtures was not tested in each pump, similar mixtures were evaluated in both pumps and mixture No. 13 was tested in both. Laboratory pump No. 1 leaked badly and subsequently failed or experienced difficulty in pumping those mixtures with larger slumps and smaller cementitious contents (mixtures No. 1, 4, 11, and 12). Mixture No. 5 proved to be pumpable only after the addition of a pump aid admixture. Each of the mixtures tested in laboratory pump No. 2 pumped successfully. Although small amounts of bleed water were noted at some of the couplings, no stoppages occurred in this pump. Aggregate type had no apparent effect on the pumpability of any of the mixtures tested in either pump.

19. Figure 4 presents the laboratory results based on the relationship established by Browne and Bamforth (1977). The plotted data indicate that an extension of the pumpability zone, as shown by the dashed curve in the figure, is necessary for laboratory pump No. 1. Air entrainment in the mixtures tested may be responsible for this extension. The Browne and Bamforth original zone of pumpability was established from test results obtained from nonair-entrained concrete mixtures (Saucier 1977). Laboratory pump No. 2 pumped all mixtures tried. Therefore, a zone of "nonpumpability" could not be defined for laboratory pump No. 2. These results suggest that the pressure bleed test may accurately evaluate the relative pumpability of air-entrained concrete mixtures when they are to be pumped in poorly maintained and leaky pumps.

Field study

20. The pressure bleed test results obtained at both the Morganza Control Structure and the Clarence Cannon Re-Regulating Dam are presented in Table 11. No difficulty in pumping the respective concrete mixtures was experienced by field pump No. 1 (Morganza Control Structure) or field




Figure 4. Bleed tests results

pump No. 2 (Clarence Cannon Re-Regulating Dam). The field test data are plotted in Figure 4. A zone of nonpumpability also could not be defined for field pump No. 1 or field pump No. 2 since both successfully pumped the respective concrete mixtures. No significant changes in pressure bleed test results were noted between the unmodified Clarence Cannon mixture and Clarence Cannon wet-sieved mixture.

21. The values of $V_{140} - V_{10}$ generally increased as the air contents of both laboratory and field mixtures increased showing that, according to the Browne and Bamforth relationship, the use of an air-entraining admixture enhances the pumpability of a concrete mixture.

Checklist Analysis

Laboratory study

22. The results of the analyses of the mixtures investigated in the laboratory are given in Table 12. The individual mixture evaluation sheets are shown in Figures 5-18. Six of the mixtures were rated either "not good" (NG) or "OK." The remaining eight mixtures were rated "borderline" (?) because their characteristics taken collectively were neither highly favorable nor unfavorable. For example, mixtures No. 3, 4, 5, 6, 8, 9, 10, and 11 generally had favorable characteristics for pumping, but were deficient in cement or fines. The three mixtures which were rated "not good" were deficient in cement and fines, and contained aggregates which fell below the established grading boundary limit. The three mixtures rated "OK" had only questionable coarse aggregate shape and grading.

Field study

23. The results of the checklist analyses of the field concrete mixtures are also given in Table 12. The individual mixture evaluation sheets are shown in Figures 19 and 20. The Morganza Control Structure mixture was rated "borderline" due to its apparent deficiency in portland cement and fines. The Clarence Cannon Re-Regulating Dam mixture was rated "OK" and was questionable only with respect to aggregate shape and coarse aggregate grading.

MIXTURE NO. 1
(Did Not Pump)

		(38.1 mm)	(100 mm)			
		MIN.				
		1-1/2" MSA, N WT, 4" LINE DIA				
CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC ADJUSTMENT
CA/TA RATIO (BY VOLUME)	50% / LARGER MSA TO 65% / MORE RD AGG					
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	60% 2.79			X	
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	15 3		X		
CEMENT OR EQUIV CONTENT	470 lb (213 kg)	400 lb (181 kg)	X			
GRADATION CURVE	ABOVE BOUNDARY LIMIT			X		
SLUMP	2-6 IN. (5-15 cm)	7 in. (18 cm)	X			
AIR CONTENT	6% MAX	4.5%			X	
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X	
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Natural Natural			X	
ADMIXTURES	AEA				X	
EVALUATION OF PUMPABILITY			X			





Figure 5. Checklist analysis worksheet, mixture No. 1

MIXTURE NO. 2
(Pumped)

		(38.1 mm)	(100 mm)					
		MIN. LINE DIA						
		1-1/2" MSA, N. WT, 4"						
CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC	ADJUSTMENT	
CA/TA RATIO (BY VOLUME)	50% LARGER MSA TO MORE RD AGG 65% LOW FM OF FA							
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	60% 2.79				X		
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	15		X				
CEMENT OR EQUIV CONTENT	470 lb (213 kg)	400 lb (181 kg)	X					
GRADATION CURVE	ABOVE BOUNDARY LIMIT			X				
SLUMP	2-6 IN. (5-15 cm)	5 in. (12.5 cm)				X		
AIR CONTENT	6% MAX	7.5%	X					
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION					X		
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Natural				X		
ADMIXTURES	AEA					X		
EVALUATION OF PUMPABILITY			X					



MIXTURE NO. 3
(Pumped)

(38.1 mm) (100 mm)
MIN.
1-1/2" MSA, N WT, 4" LINE DIA

CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC ADJUSTMENT
CA/TA RATIO (BY VOLUME)	50% / LARGER MSA TO MORE RD AGG 65% / LOW FM OF FA	60%			X	
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	2.79			X	
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	15	X	X		
CEMENT OR EQUIV CONTENT	470 lb (213 kg)	400 lb (181 kg)	X			
GRADATION CURVE	ABOVE BOUNDARY LIMIT			X		
SLUMP	2-6 IN. (5-15 cm)	3 in. (7.5 cm)			X	
AIR CONTENT	6% MAX	3.0%			X	
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X	
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Natural			X	
ADMIXTURES	AEA, HRWR				X	
EVALUATION OF PUMPABILITY				X		




Figure 7. Checklist analysis worksheet, mixture No. 3

MIXTURE NO. 4
(Did Not Pump)

		(38.1 mm)	(100 mm)			
		1-1/2" MSA, N WT, 4" MIN. LINE DIA				
CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC ADJUSTMENT
CA/TA RATIO (BY VOLUME)	50% / LARGER MSA TO MORE RD AGG 65% / LOW FM OF FA	50%		X		
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	2.79			X	
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	15	X	X		
CEMENT OR EQUIV CONTENT	470 lb (213 kg)	400 lb (181 kg)	X			
GRADATION CURVE	ABOVE BOUNDARY LIMIT			X		
SLUMP	2-6 IN. (5-15 cm)	3-3/4 in. (9.5 cm)			X	
AIR CONTENT	6% MAX	5.3%			X	
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X	
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Natural Natural			X X	
ADMIXTURES	AEA				X	
EVALUATION OF PUMPABILITY				X		




Figure 8. Checklist analysis worksheet, mixture No. 4

MIXTURE NO. 5
(Pumped)

		(38.1 mm)	(100 mm)				
		MIN. LINE DIA					
1-1/2" MSA, N WT, 4"							
CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC ADJUSTMENT	
CA/TA RATIO (BY VOLUME)	50% / LARGER MSA TO MORE RD AGG 65% / LOW FM OF FA	50%		X			
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	2.79			X		
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	15		X			
CEMENT OR EQUIV CONTENT	470 lb (213 kg)	400 lb (181 kg)	X				
GRADATION CURVE	ABOVE BOUNDARY LIMIT			X			
SLUMP	2-6 IN. (5-15 cm)	5 in. (12.5 cm)			X		
AIR CONTENT	6% MAX	6.5%		X			
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X		
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Natural			X		
ADMIXTURES	AEA, Pump Aid				X		
EVALUATION OF PUMPABILITY				X			




Figure 9. Checklist analysis worksheet, mixture No. 5

MIXTURE NO. 6
(Pumped)

		(38.1 mm)	(100 mm)			
		1-1/2" MSA, N WT,	4" MIN. LINE DIA			
CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC ADJUSTMENT
CA/TA RATIO (BY VOLUME)	50% / LARGER MSA TO 65% / MORE RD AGG					
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	57% 2.79			X	
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	15 3		X	X	
CEMENT OR EQUIV CONTENT	470 lb (213 kg)	650 lb (295 kg)			X	650-470 = 6.5% 2773(TA)
GRADATION CURVE	ABOVE BOUNDARY LIMIT			X	X	
SLUMP	2-6 IN. (5-15 cm)	6-3/4 in. (17 cm)		X		
AIR CONTENT	6% MAX	3.5%			X	
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X	
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Natural Natural			X	
ADMIXTURES	AEA, Steel Fibers			X		
EVALUATION OF PUMPABILITY				X		




Figure 10. Checklist analysis worksheet, mixture No. 6

MIXTURE NO. 7
(Pumped)

		(38.1 mm)	(100 mm)			
		1-1/2" MSA, N WT, 4"		MIN. LINE DIA		
CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC ADJUSTMENT
CA/TA RATIO (BY VOLUME)	50% / LARGER MSA TO 65% / MORE RD AGG LOW FM OF FA	60%			X	
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	2.79			X	
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	15		X	X	
CEMENT OR EQUIV CONTENT	470 lb (213 kg)	518 lb (235 kg)			X	518-470 = 1.5% 3192(TA)
GRADATION CURVE	ABOVE BOUNDARY LIMIT			X		
SLUMP	2-6 IN. (5-15 cm)	3 in. (7.5 cm)			X	
AIR CONTENT	6% MAX	4.6%			X	
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X	
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Natural			X	
ADMIXTURES	AEA, Fly Ash				X	
EVALUATION OF PUMPABILITY					X	




Figure 11. Checklist analysis worksheet, mixture No. 7

MIXTURE NO. 8
(Pumped)

		(38.1 mm)	(100 mm)					
		MIN.						
		1-1/2" MSA, N WT, 4" LINE DIA						
CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC	ADJUSTMENT	
CA/TA RATIO (BY VOLUME)	50% ^{LARGER MSA} TO ^{MORE RD AGG} 65% ^{LOW FM OF FA}	58%			X			
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	3.03			X			
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	18 9			X X			
CEMENT OR EQUIV CONTENT	470 lb (213 kg)	400 lb (181 kg)	X					
GRADATION CURVE	ABOVE BOUNDARY LIMIT			X				
SLUMP	2-6 IN. (5-15 cm)	4 in. (10 cm)			X			
AIR CONTENT	6% MAX	4.4			X			
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X			
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Crushed Crushed	X	X				
ADMIXTURES	AEA				X			
EVALUATION OF PUMPABILITY				X				




Figure 12. Checklist analysis worksheet, mixture No. 8

MIXTURE NO. 9
(Pumped)

		(38.1 mm)	(100 mm)
		1-1/2" MSA, N WT, 4" MIN. LINE DIA	
CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG ? OK REC ADJUSTMENT
CA/TA RATIO (BY VOLUME)	50% / LARGER MSA TO MORE RD AGG 65% / LOW FM OF FA	50%	X
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	3.03	X
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	18	X
CEMENT OR EQUIV CONTENT	470 lb (213 kg)	400 lb (181 kg)	X
GRADATION CURVE	ABOVE BOUNDARY LIMIT		X
SLUMP	2-6 IN. (5-15 cm)	2-1/4 in. (5.5 cm)	X
AIR CONTENT	6% MAX	3.5%	X
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION		X
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Crushed Crushed	X
ADMIXTURES	AEA		X
EVALUATION OF PUMPABILITY			X




Figure 13. Checklist analysis worksheet, mixture No. 9

MIXTURE NO. 10
(Pumped)

		(38.1 mm)	(100 mm)					
		MIN. LINE DIA						
1-1/2" MSA, N WT, 4"								
CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC ADJUSTMENT		
CA/TA RATIO (BY VOLUME)	50% / LARGER MSA TO MORE RD AGG							
	65% / LOW FM OF FA	50%			X			
FM OF FA	N. WT. 2.4 - 3.0	3.03			X			
	LT. WT. 2.2 - 2.8							
CUM % FA PASSING	#50 SIEVE 15-30%	18			X			
	#100 SIEVE 5-10%	9			X			
CEMENT OR EQUIV CONTENT	470 lb (213 kg)	400 lb (181 kg)	X					
GRADATION CURVE	ABOVE BOUNDARY LIMIT			X				
SLUMP	2-6 IN. (5-15 cm)	3-1/4 in. (8.5 cm)			X			
AIR CONTENT	6% MAX	2.5%			X			
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X			
AGGREGATE SHAPE	ROUNDED OR CA	Crushed	X	X				
	IRREGULAR FA	Crushed						
ADMIXTURES	AEA, Pump Aid				X			
EVALUATION OF PUMPABILITY				X				




Figure 14. Checklist analysis worksheet, mixture No. 10

MIXTURE NO. 11
(Pumped With Difficulty)

		(38.1 mm)	(100 mm)			
		MIN.				
		1-1/2" MSA, N WT, 4" LINE DIA				
CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC ADJUSTMENT
CA/TA RATIO (BY VOLUME)	50% / LARGER MSA TO MORE RD AGG 65% / LOW FM OF FA	50%			X	
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	3.03			X	
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	18 9			X X	
CEMENT OR EQUIV CONTENT	470 lb (213 kg)	400 lb (181 kg)	X			
GRADATION CURVE	ABOVE BOUNDARY LIMIT			X		
SLUMP	2-6 IN. (5-15 cm)	4-1/2 in. (11.5 cm)			X	
AIR CONTENT	6% MAX	3.5%			X	
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X	
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Crushed Crushed	X	X		
ADMIXTURES	AEA				X	
EVALUATION OF PUMPABILITY				X		




Figure 15. Checklist analysis worksheet, mixture No. 11

MIXTURE NO. 12
(Did Not Pump)

		(38.1 mm)	(100 mm)				
		1-1/2"	2" MSA, N WT, 4"	MIN. LINE DIA			
CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC ADJUSTMENT	
CA/TA RATIO (BY VOLUME)	50% / LARGER MSA TO MORE RD AGG 65% / LOW FM OF FA	50%			X		
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	3.03			X		
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	18 9			X X		
CEMENT OR EQUIV CONTENT	470 lb (213 kg) ABOVE BOUNDARY LIMIT	400 lb (181 kg)	X				
GRADATION CURVE				X			
SLUMP	2-6 IN. (5-15 cm)	6-1/4 in. (16 cm)	X				
AIR CONTENT	6% MAX	2.5%			X		
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X		
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Crushed Crushed	X	X			
AD MIXTURES	AEA, Pump Aid				X		
EVALUATION OF PUMPABILITY			X				




Figure 16. Checklist analysis worksheet, mixture No. 12

MIXTURE NO. 13
(Pumped)

(38.1 mm) (100 mm)
1-1/2" MSA, N WT, 4" MIN. LINE DIA

CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC ADJUSTMENT
CA/TA RATIO (BY VOLUME)	50% / LARGER MSA TO 65% / MORE RD AGG LOW FM OF FA	58%			X	
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	3.03			X	
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	18 9			X	
CEMENT OR EQUIV CONTENT	470 lb (213 kg) ABOVE BOUNDARY LIMIT	518 lb (235 kg)			X	518-470 = 48 3082 = 1.6%
GRADATION CURVE				X		
SLUMP	2-6 IN. (5-15 cm)	4-1/2 in (11.5 cm)			X	
AIR CONTENT	6% MAX	2.4%			X	
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X	
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Crushed Crushed		X		
ADMIXTURES	AEA, Fly Ash				X	
EVALUATION OF PUMPABILITY					X	




Figure 17. Checklist analysis worksheet, mixture No. 13

MIXTURE NO. 14
(Pumped)

(38.1 mm) (100 mm)
1-1/2" MSA, N WT, 4" LINE DIA

CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC ADJUSTMENT
CA/TA RATIO (BY VOLUME)	50% / LARGER MSA TO MORE RD AGG 65% / LOW FM OF FA	58%			X	
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	3.03			X	
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	18 9			X	
CEMENT OR EQUIV CONTENT	470 lb (213 kg) ABOVE BOUNDARY LIMIT	700 lb (318 kg)			X	700-470 2913(TA)=7.9%
GRADATION CURVE				X		
SLUMP	2-6 IN. (5-15 cm)	3 in. (7.5 cm)			X	
AIR CONTENT	6% MAX	4.5%			X	
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X	
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Crushed Crushed	X	X		
ADMIXTURES	AEA					
EVALUATION OF PUMPABILITY					X	




Figure 18. Checklist analysis worksheet, mixture No. 14

MORGANZA CONTROL STRUCTURE STILLING BASIN
(Pumped)

		(38.1 mm)	(125 mm)				
		1-1/2" MSA, N WT, 5" LINE DIA					
CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC ADJUSTMENT	
CA/TA RATIO (BY VOLUME)	50% LARGER MSA TO MORE RD AGG 65% LOW FM OF FA	55%			X		
FM OF FA	N. WT. 2.4 - 3.0 LT. WT. 2.2 - 2.8	2.72			X		
CUM % FA PASSING	#50 SIEVE 15-30% #100 SIEVE 5-10%	5.0 0.0	X X				
CEMENT OR EQUIV CONTENT	470 lb (213 kg)	450 lb (204 kg)	X				
GRADATION CURVE	ABOVE BOUNDARY LIMIT			X			
SLUMP	2-6 IN. (5-15 cm)	2 in. (5 cm)			X		
AIR CONTENT	6% MAX	5.0%			X		
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X		
AGGREGATE SHAPE	ROUNDED OR CA IRREGULAR FA	Natural Natural			X X		
ADMIXTURES	AEA				X		
EVALUATION OF PUMPABILITY				X			




Figure 19. Checklist analysis worksheet, Morganza Control Structure

CLARENCE CANNON RE-REGULATION DAM
(Pumped)

		(38.1 mm)	(125 mm)				
		MIN.					
		1-1/2" MSA, N WT, 5" LINE DIA					
CHARACTERISTIC	DESIRED RANGE	ACTUAL	NG	?	OK	REC ADJUSTMENT	
CA/TA RATIO (BY VOLUME)	50% / LARGER MSA						
	TO MORE RD AGG						
	65% / LOW FM OF FA	60%			X		
FM OF FA	N. WT.	2.4 - 3.0	2.48		X		
	LT. WT.	2.2 - 2.8					
CUM % FA PASSING	#50 SIEVE	15-30%	32		X		
	#100 SIEVE	5-10%	11		X		
CEMENT OR EQUIV CONTENT	470 lb (213 kg)	662 lb (300 kg)			X	662-470 2796(TA)	=6.9%
GRADATION CURVE	ABOVE BOUNDARY LIMIT			X			
SLUMP	2-6 IN. (5-15 cm)	10 cm			X		
AIR CONTENT	6% MAX	4.8%			X		
AGGREGATE SATURATION	(LT WT) - MIN OF 24 HR ASTM ABSORPTION				X		
AGGREGATE SHAPE	ROUNDED OR CA	Crushed		X			
	IRREGULAR FA	Crushed	X				
ADMIXTURES	AEA, Retarder				X		
EVALUATION OF PUMPABILITY					X		




Figure 20. Checklist analysis worksheet, Clarence Cannon Re-Regulating Dam

24. The laboratory and field data indicate that the checklist analysis is conservative in its ability to measure the relative pumpability of concrete mixtures. The relative importance of each characteristic must be considered in order to effectively rate the pumpability of a concrete mixture. For example, the amount of fines present in the mixture appears to be more significant to pumpability than does aggregate shape. No specific efforts in this investigation were directed toward determining the relative importance of the individual characteristics. Future investigations might consider addressing this question.

PART V: CONCLUSIONS AND RECOMMENDATIONS

25. If a poorly maintained and leaky pump is to be used, the Browne and Bamforth (1977) pressure bleed test apparatus will indicate the relative pumpability of various air-entrained concrete mixtures.

26. If a well maintained pump is to be used, the pressure bleed test apparatus may not accurately evaluate the pumpability of air-entrained concrete mixtures. Many mixtures which the pressure bleed test indicates are borderline or nonpumpable will actually be pumpable.

27. The personnel formulating the concrete mixture proportions, whether for a contractor mixture design or a government mixture design, will probably not know the condition of the pump to be used in the field. Therefore, the pressure bleed test might be most effectively used to provide a means for field personnel to identify those concrete mixtures that would present problems for the selected pump.

28. The checklist analysis, although conservative, should be considered for inclusion in an appropriate Engineer Manual or Engineer Technical Letter as a guide for developing pumpable concrete mixtures.

REFERENCES

American Society for Testing and Materials. 1980. "Concrete and Mineral Aggregates; Manual of Concrete Testing," 1980 Annual Book of ASTM Standards, Philadelphia, Pa.

Anderson, Wayne H. 1977. "Analyzing Concrete Mixtures for Pumpability," Journal of the American Concrete Institute, Proceedings, Vol 74, No. 9, pp 447-451.

Best, J. F. and Lane, R. O. 1980. "Testing for Optimum Pumpability of Concrete," Concrete International: Design and Construction, American Concrete Institute, Vol 2, No. 10, pp 9-17.

Browne, Roger D. and Bamforth, Phillip B. 1977. "Testing to Establish Concrete Pumpability," Journal of the American Concrete Institute, Proceedings, Vol 74, No. 5, pp 193-203.

Gray, J. E. 1962. "Laboratory Procedure for Comparing Pumpability of Concrete Mixtures," Proceedings, American Society of Civil Engineers, Vol 62.

Parker, H. W. et al. 1973. "Testing and Evaluation of Prototype Tunnel Support Systems," Report No. FRA-ORDD 74-11, Federal Railroad Administration, Department of Transportation, Washington, D. C.

Saucier, Kenneth L. 1977. "Discussion, Tests to Establish Concrete Pumpability," Journal of the American Concrete Institute, Proceedings, Vol 74, No. 11, pp 563-565.

Table 1
Chemical and Physical Properties
of Portland Cement, RC-728

<u>Chemical Properties</u>	
	<u>Percent</u>
SiO ₂	20.6
Al ₂ O ₃	4.7
Fe ₂ O ₃	3.8
CaO	64.3
MgO	1.9
SO ₃	2.9
Ignition loss	1.3
Insoluble residue	0.24
Na ₂ O	0.11
K ₂ O	0.22
Total alkali, as Na ₂ O	0.25
C ₃ S	60.1
C ₂ S	13.7
C ₃ A	6.0
C ₄ AF	11.4
<u>Physical Properties</u>	
Fineness, air permeability, cm ² /g	4090
Compressive strength, psi (MPa)	
3 days	3540 (24.4)
7 days	4480 (30.9)
Autoclave expansion, percent	-0.01
Initial setting time, hr/min	2:50
Final setting time, hr/min	4:40

Table 2
Physical Properties and Gradings
of Natural Fine and Coarse Aggregates

<u>Test</u>	<u>Fine</u> <u>(WES-1 S-4(51))</u>	<u>No. 4 to 1 in.</u> <u>(4.75 to 38.1 mm)</u> <u>(CRD G-42)</u>
Bulk specific gravity, saturated surface-dry	2.64	2.57
Absorption, %	0.2	1.9
<u>Cumulative Percent Passing</u>		
<u>Sieve size</u>		
38.1 mm (1-1/2 in.)		100
25.0 mm (1 in.)		96
19.0 mm (3/4 in.)		78
12.5 mm (1/2 in.)		46
9.5 mm (3/8 in.)		29
4.75 mm (No. 4)	98	6
2.36 mm (No. 8)	87	
1.18 mm (No. 16)	72	
600 μ m (No. 30)	46	
300 μ m (No. 50)	15	
150 μ m (No. 100)	3	
75 μ m (No. 200)		

Table 3
Physical Properties and Gradings
of Crushed Limestone Fine and Coarse Aggregates

Test	Fine (CRD MS-27)	No. 4 to 3/4 in. (4.75 to 19 mm) (CL-2 G-1)	3/4 in. to 1-1/2 in. (19.0 to 38.1 mm) (CRD G-40)	Combined* Coarse Aggregate
Bulk specific gravity, saturated surface dry	2.71	2.74	2.73	
Absorption, %	0.7	0.5	0.5	
Cumulative Percent Passing				
Sieve size				
50 mm (2 in.)			100	100
38.1 mm (1-1/2 in.)			98	99
25.0 mm (1 in.)		100	42	74
19.0 mm (3/4 in.)		98	10	59
12.5 mm (1/2 in.)		74	3	42
9.5 mm (3/8 in.)		41	2	24
4.75 mm (No. 4)	99	4	2	2
2.36 mm (No. 8)	90			
1.18 mm (No. 16)	55			
600 μ m (No. 30)	32			
300 μ m (No. 50)	18			
150 μ m (No. 100)	9			
75 μ m (No. 200)	5			

* The two size ranges of coarse aggregates were combined in the following proportions: 44 percent, 3/4 to 1-1/2 in. (19.0 to 38.1 mm); 56 percent, No. 4 to 3/4 in. (4.75 to 19.0 mm).

Table 4
Chemical and Physical Properties
of Fly Ash, AD-474

<u>Chemical Properties</u>	
	<u>Percent</u>
SiO ₂ + Al ₂ O ₃ + Fe ₂ O ₃	87.8
MgO	1.4
SO ₃	0.1
Available alkalies, as Na ₂ O	0.8
Moisture content	0.4
Ignition loss	3.8
<u>Physical Properties</u>	
Fineness, air permeability, cm ² /g	6690
Specific gravity	2.18
Lime pozzolan strength, psi (MPa), 7 days	1265 (8.72)
Autoclave expansion, percent	-0.02

Table 5
Physical Properties and Gradings of Natural
Fine and Coarse Aggregates, Morganza Control Structure

Test	Fine (NO-14 S-2)	No. 4 to 1 in. (4.75 to 25.0 mm) (NO-14 G-8)
Bulk specific gravity, saturated surface-dry	2.64	2.52
Absorption, %	0.3	2.1
<u>Cumulative Percent Passing</u>		
<u>Sieve size</u>		
38.1 mm (1-1/2 in.)		100
25.0 mm (1 in.)		96
19.0 mm (3/4 in.)		74
12.5 mm (1/2 in.)		29
9.5 mm (3/8 in.)	100	17
4.75 mm (No. 4)	97	1
2.36 mm (No. 8)	86	
1.18 mm (No. 16)	75	
600 mm (No. 30)	59	
300 mm (No. 50)	11	
150 mm (No. 100)	0	
75 mm (No. 200)		

Table 6
Chemical and Physical Properties
of Portland Cement, STL-43 C-1

<u>Chemical Properties</u>	
	<u>Percent</u>
SiO ₃	22.7
Al ₂ O ₃	4.5
Fe ₂ O ₃	3.7
CaO	63.8
MgO	1.5
SO ₃	1.6
Ignition loss	1.4
Insoluble residue	0.15
Na ₂ O	0.20
K ₂ O	0.40
Total alkali, as Na ₂ O	0.46
C ₃ S	47.5
C ₂ S	29.2
C ₃ A	5.6
C ₄ AF	11.2
<u>Physical Properties</u>	
Fineness, air permeability, cm ² /g	3700
Compressive strength, psi (MPa)	
3 days	2200 (15.2)
7 days	3550 (24.5)
Autoclave expansion, percent	-0.01
Initial setting time, hr/min	2:50
Final setting time, hr/min	5:30

Table 7

Physical Properties and Gradings of Crushed Limestone Fine
and Coarse Aggregates, Clarence Cannon Reservoir, Re-Regulation Dam

Test	Fine (STL-43 MS-1)	No. 4 to 3/4 in. (4.75 to 19.0 mm) (STL-43 G-1)	3/4 in. to 1-1/2 in. (19.0 to 38.1 mm) (STL-43 G-1)	Combined* Coarse Aggregate
Bulk specific gravity, saturated surface-dry	2.64	2.63	2.65	
Absorption, %	1.6	1.7	1.1	
<u>Sieve size</u>				
50 mm (2 in.)			100	100
38.1 mm (1-1/2 in.)			99	100
25.0 mm (1 in.)		100	42	74
19.0 mm (3/4 in.)		91	8	54
12.5 mm (1/2 in.)		52	3	30
9.5 mm (3/8 in.)		31	2	18
4.75 mm (No. 4)	100	8	2	5
2.36 mm (No. 8)	92	5		3
1.18 mm (No. 16)	76			
600 μ m (No. 30)	48			
300 μ m (No. 50)	26			
150 μ m (No. 100)	11			
75 μ m (No. 200)	6			

* The two size ranges of coarse aggregates were combined in the following proportions: 45 percent, 3/4 to 1-1/2 in. (19.0 to 38.1 mm); 55 percent, No. 4 to 3/4 in. (4.75 to 19.0 mm).

Table 8
Laboratory Study Mixture Proportions

Mix- ture No.		Material									
		Portland Cement	Fly Ash	Fine Aggregate	Coarse Aggregate	Water	Air	Pumping Aid	High-Range Water-Reducing Admixture	Steel Fibers	Total
1	Solid volume, ft ³ (m ³)	2.035 (0.058)		8.036 (0.228)	12.053 (0.341)	3.526 (0.100)	1.350 (0.038)				27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	400.0 (237.3)		1323.8 (785.4)	1932.9 (1146.7)	220.0 (130.5)					3876.7 (2300.0)
2	Solid volume, ft ³ (m ³)	2.035 (0.058)		8.087 (0.229)	12.125 (0.343)	3.397 (0.096)	1.350 (0.038)				27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	400.0 (237.3)		1332.3 (3090.3)	1944.5 (1153.6)	212.0 (125.8)					3888.8 (2307.1)
3	Solid volume, ft ³ (m ³)	2.035 (0.058)		8.226 (0.234)	12.400 (0.351)	2.949 (0.084)	1.350 (0.038)		7.2 (4.3)		27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	400.0 (237.3)		1343.9 (797.3)	1962.6 (1164.4)	176.8 (104.9)					3890.5 (2308.1)
4	Solid volume, ft ³ (m ³)	2.035 (0.058)		10.109 (0.286)	10.109 (0.286)	3.397 (0.096)	1.350 (0.038)				27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	400.0 (237.3)		1659.0 (984.2)	1608.5 (954.3)	212.0 (125.8)					3879.5 (2301.6)
5	Solid volume, ft ³ (m ³)	2.035 (0.058)		10.109 (0.286)	10.109 (0.286)	3.397 (0.096)	1.350 (0.038)	0.4 (0.2)			27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	400.0 (237.3)		1659.0 (984.2)	1608.5 (954.3)	211.6 (125.5)					3879.5 (2301.6)
6	Solid volume, ft ³ (m ³)	3.307 (0.094)		7.350 (0.208)	9.742 (0.276)	5.000 (0.142)	1.350 (0.038)			0.251 (0.007)	27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	650.0 (385.6)		1210.8 (718.3)	1562.3 (926.9)	312.0 (185.1)				120.0 (71.2)	3855.1 (2287.1)

(Continued)

Table 8 (Continued)

Mix- ture No.		Material								Total
		Portland Cement	Fly Ash	Fine Aggregate	Coarse Aggregate	Water	Air	Pumping Aid	High-Range Water-Reducing Admixture	
7	Solid volume, ft ³ (m ³)	2.646 (0.075)		7.875 (0.223)	11.812 (0.334)	3.317 (0.094)	1.350 (0.038)			27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	517.5 (307.0)		1297.3 (769.7)	1894.3 (1123.8)	207.0 (122.8)				3916.1 (2323.3)
8	Solid volume, ft ³ (m ³)	2.035 (0.058)		7.951 (0.225)	10.979 (0.311)	4.551 (0.129)	1.485 (0.042)			27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	400.0 (237.3)		1344.5 (797.7)	1874.1 (1111.9)	284.0 (168.5)				3902.6 (0.765)
9	Solid volume, ft ³ (m ³)	2.035 (0.058)		9.465 (0.268)	9.464 (0.268)	4.551 (0.129)	1.485 (0.042)			27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	400.0 (237.3)		1600.5 (949.5)	1615.5 (958.4)	284.0 (168.5)				3900.0 (2313.8)
10	Solid volume, ft ³ (m ³)	2.035 (0.058)		9.465 (0.268)	9.464 (0.268)	4.551 (0.129)	1.485 (0.042)			27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	400.0 (237.3)		1600.5 (949.5)	1615.5 (958.4)	283.6 (168.3)		0.4 (0.2)		3900.0 (2313.8)
11	Solid volume, ft ³ (m ³)	2.035 (0.058)		9.401 (0.266)	9.400 (0.266)	4.679 (0.132)	1.485 (0.042)			27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	400.0 (237.3)		1589.7 (943.1)	1604.6 (952.0)	292.0 (173.2)				3886.3 (2305.6)
12	Solid volume, ft ³ (m ³)	2.035 (0.058)		9.401 (0.266)	9.400 (0.266)	4.679 (0.132)	1.485 (0.042)			27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	400.0 (237.3)		1589.7 (943.1)	1604.6 (952.0)	291.6 (173.0)		0.4 (0.2)		3886.3 (2305.6)

(Continued)

Table 8 (Concluded)

Mix- ture No.		Material									
		Portland Cement	Fly Ash	Fine Aggregate	Coarse Aggregate	Water	Air	Pumping Aid	High-Range Water-Reducing Admixture	Steel Fibers	Total
13	Solid volume, ft ³ (m ³)	2.127 (0.060)	0.742 (0.021)	7.613 (0.216)	10.514 (0.298)	4.519 (0.128)	1.485 (0.042)				27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	418.0 (248.0)	100.9 (59.9)	1287.4 (763.8)	1794.7 (1064.8)	282.0 (167.3)					3883.0 (2303.7)
14	Solid volume, ft ³ (m ³)	3.561 (0.101)		7.195 (0.204)	9.935 (0.281)	4.824 (0.137)	1.485 (0.042)				27.000 (0.765)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	700.0 (415.3)		1216.7 (721.8)	1696.0 (1006.2)	301.0 (178.6)					3913.7 (2321.9)

Table 9
Field Study Mixture Proportions

Project		Material					
		Portland Cement	Fly Ash	Fine Aggregate	Coarse Aggregate	Water	Air Total
Morganza Control Structure	Solid volume, ft ³ (m ³)	2.289 (0.065)		8.782 (0.247)	10.733 (0.304)	3.846 (0.109)	1.350 (0.038)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	450.0 (267.0)		1447.0 (838.5)	1668.0 (1001.5)	240.0 (142.4)	3825.0 (2289.3)
Clarence Cannon Re-Regulating Dam	Solid volume, ft ³ (m ³)	3.369 (0.095)		6.790 (0.192)	10.185 (0.288)	5.306 (0.150)	1.350 (0.038)
	Bulk density, saturated surface-dry, lb/yd ³ (kg/m ³)	662.2 (392.9)		1118.6 (663.6)	1677.2 (995.0)	331.1 (196.4)	3789.1 (2248.0)

Table 10
Results of Pressure Bleed Tests Conducted in the Laboratory Study

Mixture No.	Aggregate Type	Cementitious Material Content lb/yd ³	Cementitious Material Content kg/m ³	Water-Cementitious Material Ratio by Mass	Sand-Aggregate Ratio Percent by Volume	Slump		Air Content Pressure Method Percent	Water Emitted, V ₁₄₀ - V ₁₀		Type Admixture
						in.	mm		oz	cm ³	
Laboratory Pump No. 1											
1	Natural	400	237	0.55	40	7	175	4.5	1.4	43	Air entraining
4	Natural	400	237	0.53	50	3-3/4	95	5.3	1.8	55	Air entraining
5	Natural	400	237	0.53	50	5	125	6.5	2.5	75	Air entraining, pumping aid
7	Natural	518	307	0.40	40	3	75	4.6	2.1	63	Air entraining
11	Crushed	400	237	0.73	50	4-1/2	115	3.5	2.3	68	Air entraining
12	Crushed	400	237	0.73	50	6-1/4	160	2.5	2.4	71	Air entraining, pumping aid
13	Crushed	518	307	0.50	42	4-3/4	120	2.7	3.5	105	Air entraining, fly ash
14	Crushed	700	415	0.43	42	3	75	4.5	2.7	80	Air entraining
Laboratory Pump No. 2											
2	Natural	400	237	0.53	40	5	125	3.6	2.0	60	Air entraining
3	Natural	400	237	0.46	40	3	75	3.0	1.4	41	Air entraining, high-range water-reducing
6	Natural	650	386	0.48	43	6-3/4	170	3.5	2.3	68	Air entraining, steel fibers
8	Crushed	400	237	0.71	42	4	100	4.4	2.8	82	Air entraining
9	Crushed	400	237	0.71	50	2-1/4	55	3.5	3.1	93	Air entraining
10	Crushed	400	237	0.71	50	3-1/4	85	2.5	2.3	67	Air entraining, pumping aid
13	Crushed	518	307	0.50	42	4-1/2	115	2.4	3.5	105	Air entraining, fly ash

Table 11
Results of Pressure Bleed Tests Conducted in the Field Study

Project	Aggregate Type	Cement Content lb/yd ³	Cement Content kg/m ³	Water-Cement Ratio by Mass	Sand-Aggregate Ratio Percent by Volume	Slump in. mm	Air Content Pressure Method Percent	Water		Type Admixture
								V ₁₄₀ - V ₁₀ oz	Emitted cm ³	
Field Pump No. 1										
Morganza Control Structure	Natural	450	267	0.53	45	2 50	5.0	1.3	40	Yes
						3 75	5.0	2.0	59	Yes
Field Pump No. 2										
Clarence Cannon Ke-Regulating Dam	Crushed	662	393	0.50	37	4 100	7.0	2.3	68	Yes
						4 100	4.8	1.3	40	Yes
						4 100*	5.6	1.7	50	
										Air entraining, retarding

* Wet-sieved over a 25.0-mm (1-in.) sieve.

Table 12
Relative Pumpability of Laboratory and
Field Mixtures Based on the Checklist Analysis

Mixture No.	Pumped Successfully	Checklist Analysis		
		Not Good	?	OK
<u>Laboratory Pump No. 1</u>				
1	No	X		
4	No		X	
5	Yes		X	
7	Yes			X
11	With difficulty		X	
12	No	X		
13	Yes			X
14	Yes			X
<u>Laboratory Pump No. 2</u>				
2	Yes	X		
3	Yes		X	
6	Yes		X	
8	Yes		X	
9	Yes		X	
10	Yes		X	
13	Yes			X
<u>Field Pump No. 1</u>				
	Yes		X	
<u>Field Pump No. 2</u>				
	Yes			X

In accordance with letter from DAEN-RDC, DAEN-ASI dated 22 July 1977, Subject: Facsimile Catalog Cards for Laboratory Technical Publications, a facsimile catalog card in Library of Congress MARC format is reproduced below.

Ragan, Steven A.

Evaluation of tests for determining the pumpability of concrete mixtures / by Steven A. Ragan (Structures Laboratory, U.S. Army Engineer Waterways Experiment Station). -- Vicksburg, Miss. : The Station ; Springfield, Va. : available from NTIS, 1981.

50 p. : ill. ; 27 cm. -- (Miscellaneous paper / U.S. Army Engineer Waterways Experiment Station ; SL-81-29)
Cover title.

"October 1981."

Final report.

"Prepared for Office, Chief of Engineers, U.S. Army under CWIS Work Unit No. 31138."

Bibliography: p. 36.

1. Concrete research. 2. Concrete--Mixing.
3. Concrete--Testing. I. United States. Army. Corps of Engineers. Office of the Chief of Engineers. II. U.S.

Ragan, Steven A.

Evaluation of tests for determining : ... 1981.
(Card 2)

Army Engineer Waterways Experiment Station. Structures Laboratory. III. Title IV. Series: Miscellaneous paper (U.S. Army Engineer Waterways Experiment Station) ; SL-81-29.
TA7.W34m no.SL-81-29

DATE
FILMED
— 8